

U.S. Department of Labor  
Occupational Safety and Health Administration

Inspection Number: 1554040  
Inspection Date(s): 09/16/2021 - 09/16/2021  
Issuance Date: 03/14/2022



**Notice of Unsafe or Unhealthful Working Conditions**

**Company Name:** Tennessee Valley Authority, dba TVA  
**Inspection Site:** 1265 Edgemoor Road, Clinton, TN 37716

---


Notice 1 Item 1      Type of Violation: **Willful - Serious**

29 CFR 1926.501(a)(2): The employer did not determine if the walking/working surfaces on which its employees were to work on, had the strength and structure integrity to support employees safely. Employees were allowed to work on surfaces which did not have the requisite strength and structural integrity:

a) On or about September 16, 2021 at the Bull Run Power Plant "Charlie" and "Delta" precipitator insulation project employees were exposed to fall and laceration hazards while on double and quadruple electrical insulator compartments and the employer did not determine if the walking/working surfaces on which its employees were to work on, had the strength and structure integrity to support employees safely. Sub-contractor employees were allowed to walk and work on insulator compartments which did not have the requisite strength and structural integrity.

**ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM**

**Date By Which Violation Must be Abated: March 24, 2022**

  
\_\_\_\_\_  
**William Cochran**  
Area Director